

Reference Number	Public Water Supply Zone	Ref	Parameter & PCV	Solution	Legal Instrument	Obligation Date
ANG3382	East Harling	NE40	Clopyralid 0.1µg/l & total pesticides 0.5µg/l	Catchment Management	Undertaking	31/03/2020
ANG3383	Bourne	KN60	Metaldehyde 0.1µg/l & total pesticides 0.5µg/l	Catchment Management	Undertaking	31/03/2020
	Holbeach	KN64				
	Market Deeping	KN63				
ANG3384	Tiptree	ES36	Metaldehyde 0.1µg/l, Clopyralid 0.1µg/l & total pesticides	Catchment Management	Undertaking	31/03/2020
ANG3336	Amphill	MW34	Metaldehyde 0.1µg/l, Clopyralid 0.1µg/l & total pesticides 0.5µg/l	Catchment Management	Undertaking	31/03/2020
	Barrowby	KN42				
	Beanfield	RW53				
	Bedford Rural	MW23				
	Bedford Urban Central	MW26				
	Bedford Urban South	MW25				
	Belstead	SS18				
	Biggleswade	MW36				
	Billinghay	KN78				
	Boston	KN70				
	Bourne	KN60				
	Brigg	LN65				
	Brixworth	RW11				
	Buckingham	RW20				
	Caistor	LN02				
	Chalton	RW52				
	Cleethorpes	LN24				
	Colchester South	ES41				
	Daventry	RW14				
	Desborough	RW08				
	Etton	FW03				
	Felixstowe	SS22				
	Fulstow	LN11				
	Grantham Central	KN51				
	Grimsby North	LN17				
	Grimsby South	LN67				
	Harpswell	LN45				
	Heigham	NE14				
	Holbeach	KN64				
	Huntingdon North	FW40				
	Huntingdon South	FW41				
	Ipswich East	SS42				
	Ipswich South	SS44				
	Kettering Town West	RW45				
	Kings Lynn	FE47				
	Lakenham	NE58				
	Leighton Linlade	MW38				
	Lexden	ES38				
	Lincoln South	LN69				
	Lincoln Westgate	LN72				
	Louth	LN23				
	Mablethorpe	LN19				
	Mancroft	NE54				
	March	FE52				
	Marham	FE64				
	Market Deeping	KN63				
	Middleton	FE61				
	Milton Keynes City North	MW29				
	Milton Keynes City North West	MW28				
	Milton Keynes City South East	MW31				
	Mumby	LN20				
	Newport Pagnell	MW21				
	Northampton Central	RW16				
	Northampton East	RW18				
	Northampton North	RW19				
	Northampton South	RW17				
	Northampton West	RW15				
	Oundle	RW44				
	Peterborough City	FW49				
	Peterborough City North	FW51				
	Peterborough City West	FW47				
Peterborough	FW02					
Pilsgate	KN79					
Plumstead	NE59					
Raunds Rural	RW13					
Ravensthorpe	RW10					
Raydon/Alton	SS21					
Rushmere Rural	SS45					
Sandhouse	MW52					
Sandy	MW46					
Saxilby	LN34					
Scunthorpe North	LN28					
Skegness	LN26					
Sleaford	KN31					
Spilsby	LN09					
Wellingborough	RW07					
Welton	LN48					
West Bergholt	ES37					
Whittlesey	FE50					
Winslow	MW27					
Winterton	LN27					
Wisbech	FE48					
ANG3327	Scunthorpe North	LN28	Bentazone 0.1µg/l, Clopyralid 0.1µg/l & total pesticides 0.5µg/l	Blending	Regulation 28 Notice	30/04/2019
	Winterton	LN27				

ANG3335	Public buildings within Anglian Water Public Water Supply Zones	All	Clostridium perfringens, coliform bacteria, E. coli, Enterococci, Taste and Odour, Sodium, Copper, Nickel	Risk Assessments, Inspections/ Investigations Customer awareness	Regulation 28 Notice	31/10/2020
ANG3329	Ixworth	SS06	Nitrate	Ion Exchange	Regulation 28 Notice	31/01/2019
ANG3331	Semer	SS26	Nickel	Blending	Regulation 28 Notice	31/07/2019
ANG3328	Retford	LN38	Nitrate	Ion Exchange	Regulation 28 Notice	31/04/2018
ANG3338	Brixworth	LN38	Carbetamide 0.1µg/l, Metazachlor 0.1µg/l and Total Pesticides 0.5µg/l	GAC Replacement	Regulation 28 Notice	30/04/2021
	Daventry	RW14				
	Northampton Central	RW16				
	Northampton North	RW19				
	Northampton West	RW15				
ANG3337	Bury St. Edmunds	SS07	Metaldehyde 0.1µg/l & total pesticides 0.5µg/l	Blending	Regulation 28 Notice	30/04/2021
	Haverhill	SS23				
ANG3546	Ely	FE33	Nitrate	Ion Exchange	Regulation 28 Notice	31/01/2019
	Eriswell/Mildenhall	FS02				
ANG3332	Mundesley	NE06	Lead 10µg/l	Uprate plumbosolvency treatment	Regulation 28 Notice	30/04/2021
	Ely	FE33	Lead 10µg/l	Uprate plumbosolvency treatment		
	Eriswell/Mildenhall	FS02				
	Ely	FE33	Lead 10µg/l	Uprate plumbosolvency treatment		
	Ely	FE33	Lead 10µg/l	Uprate plumbosolvency treatment		
	Eriswell/Mildenhall	FS02				
	Ely	FE33	Lead 10µg/l	Uprate plumbosolvency treatment		
	Eriswell/Mildenhall	FS02				
	Clay Hill	KN81	Lead 10µg/l	Uprate plumbosolvency treatment		
	Sleaford	KN31	Lead 10µg/l	Uprate plumbosolvency treatment		
	Bourne	KN60	Lead 10µg/l	Uprate plumbosolvency treatment		
	Long Stratton	NE25	Lead 10µg/l	Uprate plumbosolvency treatment		
	Moulton/ Kennett	FS04	Lead 10µg/l	Uprate plumbosolvency treatment		
	Carbrooke	NE53	Lead 10µg/l	Install new plumbosolvency treatment		
	Dereham South	NE15				
	Kirby Cane	NE26	Lead 10µg/l	Install new plumbosolvency treatment		
	Foulsham	NE10	Lead 10µg/l	Install new plumbosolvency treatment		
	Halstead Rural	ES27	Lead 10µg/l	Install new plumbosolvency treatment		
	Halstead Urban	ES32				
	Halstead Urban	ES32	Lead 10µg/l	Install new plumbosolvency treatment		
	Rushbrooke	SS08	Lead 10µg/l	Install new plumbosolvency treatment		
	Baylham/ Kirbyrise	SS13	Lead 10µg/l	Install new plumbosolvency treatment		
	Stowmarket	SS10				
	Pettistree	SS15	Lead 10µg/l	Install new plumbosolvency treatment		
ANG3450	Belstead	SS18	Iron and Manganese	Package of measures	Regulation 28 Notice	31/01/2019
HPL3470	Wynyard	Z007	Turbidity, Iron and Manganese	Package of measures	Regulation 28 Notice	31/07/2018
HPL3508	Hartlepool PWSZ	Z008	Turbidity, Iron and Manganese	Package of measures	Regulation 28 Notice	31/05/2019